

PERMIT APPROVAL SPECIFICATIONS

Owner information:

JOHN HARRIS

Name

2957 HWY 200

Mailing address

TROUT CREEK

City

04-102 lodge

Permit Number

17 24 31

S T R

JAN 22 04

Date Submitted

FEB 6 04

Date Approved

02 06 04

Expiration Date

Permit Specifications:

This permit is approved with the following specifications:

see DEQ approval

size of septic tank

see DEQ approval

lineal feet of drainfield

(see DEQ approval: square feet of drainfield)

YES any special design for the system. List design specifications:

Install a DEQ 4, 2002 ed. Standard Absorption Trench System. Remember to keep the trenches no deeper than 36 inches. Install laterals in 4 trenches, each trench 60 feet in length and 2 feet wide. Install the system exactly as per approved lot layout. Pre-notification is mandatory before backfilling system.

attached 4 pages of the DEQ approval (NO 2/6/04). please reference the

JH

Initials of Sanitarian

AS-BUILT SKETCH
AND
STATEMENT OF ACCURACY OF INSTALLATION

JUN 4 2004

Land owner's name John Harris

Permit number 04-102 ledge

I, Scott Gilbert, as the licensed installer for the
(Printed Name of Installer)
following system have constructed or altered the septic system of
the above noted parcel.

I do hereby declare that the EXACT specifications of the approved
permit issued have been followed. Accompanying this statement is
a copy of the lot layout to file in the Courthouse Environmental
Health office. This statement and the "as-built" sketch on the
back of this page or attached to this page shall be submitted to
the Environmental Health office within ten (10) days of
completion of the system.

Installer's Signature Scott Gilbert

Installer's License Number TC-31

Completion Date of System 5-20-04

Checklist of as-built sketch:

- ☒ North arrow
- ☒ triangular measurements from two corners of house to
tank access
- ☒ measurement of pipe from tank to D-box or manifold
- ☒ all parcel boundaries
- ☒ distance between the system and at least two parcel
boundaries

Additional information needed (fill this out):

60' length of drainfield laterals
4 number of drainfield laterals
2-1000 gal tanks volume of septic tank

file reg/as-builts form

1875

1875


W. Harris

SKETCH

JUN

4-102 Lakeside Lodge



JUN 4 2004



As-Built of existing system.

John Harris
04-102 Lakeside Lodge

JUN 4 2004



MAY 17 2004

Notification from Licensed Installer

The following information was given by the installer:

Scott Gilbert Installer's Name
Lakeside Motel, Trout Creek Property owner's name
John Harris General location of system
04-102 Permit number (Found in upper right
hand corner of permit)
827-4495 Phone number of installer
8-A - 5PM Time installer can be reached at above
phone number

The following information is regarding who took the message:

Mon. 5-17-04 Date of notification
8AM Time of notification
CA Initials of message-ee

Thank you. Please put this into the Sanitarian's box or in the
Sanitarian's office.

5-17 Left 1 hr. message with Kathy @ 11:35am (CA)

Sanders County Individual Wastewater Treatment System
Permit Application Revised Jun 1999

JAN 22 2004

Part I. Owner information

Property owner name

John Harris

Complete mailing address

2957 Hwy 200

(Include city and ZIP)

Trout Creek, MT. 59874

Telephone: Home

406-827-4458

Work

406-827-4458

Part II. Fees

See most recent copy of fee schedule (attached).

Part III.

If permit is to be sent to someone other than property owner:

Name

Same -

Mailing address

Same -

Same -

Part IV. Statement of accuracy and permission to inspect

I, John Harris, as the owner of the parcel of land described within the permit, have completed the permit application of Sanders County Individual Wastewater Treatment Systems. I also do hereby declare that the information provided was to the best of my knowledge. I acknowledge that the County Sanitarian and/or the Board of Health member(s) is\are hereby empowered and authorized to enter upon my private property for the purpose of inspecting a system that treats, discharges, or disposes of wastewater to determine compliance with these regulations.

John Harris

Printed name of owner

John Harris
Signature of owner

1-22-04

Date

Part IV. Parcel/Lot description

Legal description S 17 T 24 R 31 Tax Role # 10681

Physical Location 2957 Hwy 200, Trout Creek

Size or dimension of parcel or lot .304 AC

Part V. Proposed use of system:

Residential: single living unit
 number of bedrooms

 multiple living unit
 total number of bedrooms

Commercial or industrial:

 maximum discharge 330 gal/day
 how determined

Part VI. Proposed work:

 ✓ new system

 replacement system

Part VII. State or County Review or previous site evaluation

Does COS or PLAT have DHES or DEQ approval?

 ✓ yes no

If no was checked, include the following with permit application:

- "Report for site evaluation" (page 4 of application)
- completed site evaluation checklist
- completed lot layout (page 3 of application)

If ✓ yes was checked, include the following with permit application:

- ✓ copy of certificate of plat approval statement
- ✓ copy of approved lot layout

 ✓ complete the following:

Name of subdivision Lakeside Motel RV Park Beaverton
Block and/or lot number 4
COS # Date of approval 6-26-03

If the parcel of land has had either county review or a previous site evaluation, submit all applicable documentation.